



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 10/13/09

Code 48.2.6-09R

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title Table 403.1 Minimum Width of Concrete, Precast, or Masonry Footings		Page
Proponent SW Indiana Builders and Officials	Title	
Address 2175 N Cullen Ave Evansville, IN 47715 Room 310, Civic Center Complex, Evansville, IN 47708		Phone 812-479-6026 & 812-436-7868
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Add footnote to read as follows: "b) For the purposes of this table, a basement is not considered a story."		
REASON		
This amendment is part of the Seismic Package supported by home builders and building officials in the area, and is consistent to the existing standards. <i>Fiscal impact: As this seismic package is parallel to existing standards, no impact is expected.</i>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		